


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Reference: W-297214e-18-WD
Before: **W-279656e-17 Ho**
Ansprechpartner: F. Wedke B. Eng.

Certificate

(Transcription of certificate W-279656e-17-Ho)

Hygiene – conformity check

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: Plastic pipe "Fitt Air"

Manufacturer: FITT S.p.A.
Via Piave, 8
36066 SANDRIGO (VI)
Italy

Basis of the examination: VDI 6022, Blatt 1 (07/2011)
 SWKI VA104-01 (04/2006)
 ÖNorm H 6021 (09/2003)
 ÖNorm H 6038 (02/2014)

Validity period: 5 years 02/2015 – 02/2020

Test report: W-253435e-15-Ho



In conclusion it can be stated that the examined Plastic pipe "Fitt Air", as specified in the test report W-253435e-15-Ho, is in compliance with the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water
Hygiene and Environmental
Microbiology

(F. Wedke B. Eng.)
Administrator of Air Conditioning
technology
Department of Water
Hygiene and Environmental
Microbiology

issued 17.04.2018, Gelsenkirchen

Within the framework of the hygiene-type examination the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt-ID: DE125018356
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Volker Vohmann, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)